



APPROVALS®

Certificate of Approval

Certificate No.: SAA-191046-EA

Certificate Holder: ProJoy Electric Co., Ltd.
XinTang Industrial Zone,
North-city Street, PingJiang District,
Suzhou 215000
P.R. China

Class Description: Miniature Overcurrent Circuit-Breaker
Product Description: DC Miniature Circuit Breaker
Brand Name: PROJOY electric
Model No.: PEBS-H
Markings: Cat. A; 1P/2P/3P/4P;
 $U_e=250V/500V/750V/1000VDC$ (1/2/3/4P);
 $I_n=10, 16, 20, 25, 32, 40, 50, 63A$;
 $U_i=1000V$; $U_{imp}=6.0kV$; $I_{cu}=6.0kA$;
 $I_{cs}=6.0kA$ Instantaneous tripping curve:
 $I_1=8I_n$ (for C-type); $I_1=4I_n$ (for B-type)
Standard: AS/NZS IEC 60947.2:2015
Conditions: Nil

Approval Mark: SAA-191046-EA or RCM

Date First Registered: 2 May 2019

Date of Expiry: 2 May 2024

R.A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 02-05-19 191046/1



2 May 2019

ProJoy Electric Co., Ltd.
XinTang Industrial Zone,
North-city Street, PingJiang District,
Suzhou 215000
P.R. China

C/- ICAL & TRADING CO

Dear Sir

**Certificate of Approval – SAA-191046-EA
DC Miniature Circuit Breaker
Model No.: PEBS-H**

We are pleased to advise that your application for certification of the above electrical product has been successful.

Please ensure that you keep the enclosed Certificate in a safe place as it is your product approval record.

The approved product must now be marked with the SAA Number SAA-191046-EA or may be marked with the Regulatory Compliance Mark (RCM). The RCM must be used in accordance with the conditions set out in the relevant parts of AS/NZS 4417.

Please note that if the electrical product is modified in any way or your company details change you are required to notify this office of the details of the modification. You can either download the required form from our web page or contact our office.

As part of our operational guidelines we are required to check that a certified product remains compliant during the term of the Certificate. At some stage during this term we may request a sample for evaluation.

If you need any further information or need to discuss this letter please don't hesitate to contact our office.

Yours sincerely

A handwritten signature in black ink that reads 'R. A. Hill'.

**For and on behalf of
SAA Approvals Pty Ltd**

ABN 91 125 451 327

P. +61 7 3393 9455

E. +61 7 3393 9499

E. info@saaapprovals.com.au

W. www.saaapprovals.com.au

PO Box 189, Cannon Hill QLD 4170
5/20 Rivergate Place, Murarie QLD 4172