



Certificate of Conformity

Certificate No.: SAA-190350-EA

Certificate Holder: ProJoy Electric Co., Ltd.
XinTang Industrial Zone, North-city Street,
PingJiang District,
Suzhou 215000
P.R. China

Class Description: DC Isolator
Product Description: PV Switch-disconnector
Brand Name: PROJOY electric
Model No.: PEDS150a-b32c-y Series
Markings: Ui=1500Vdc; Uimp=8kV
Ue: 300/600/800/1000 DC
Ie: 10A...32A
IP66NW (For EL type - with enclosure),
IP20 (for PM, HM, DB, DC type - without enclosure),
-40 to +85°C, DC-PV2

Standard: AS 60947.3:2018
AS/NZS IEC 60947.1:2015

Conditions: Nil

Approval Mark: RCM and SAA-190350-EA

Date First Registered: 14 February 2019
Date of Expiry: 14 February 2024

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Old Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 14-02-19 190350/1

www.jas-anz.org/register



Certificate of Conformity

Addendum

Certificate No.: SAA-190350-EA

Date of Issue: 14 February 2019

Class Description: DC Isolator
Product Description: PV Switch-disconnector

General Modification:

For PEDS150a-b32c-y Series:

'a' denotes contacts and can be blank for standard contacts or 'R' for reversed contacts;

'b' denotes mounting method and can be 'PM' for panel mounting, 'HM' for single-hole mounting, 'DB' for distribution board DC isolator, 'DC' for door clutch DC isolator or 'EL' for enclosed DC isolator;

'c' denotes actuator and can be blank for without lockable rotary actuator, 'R' for with lockable rotary actuator or 'L' for lockable level actuator; and

'y' denotes different switching circuit and can be '2', '4', '4T', '4B' or '4S'.

Additional Models	Description
PEDS150a-b25c-y Series	Similar to PEDS150a-b32c-y Series except rated: Ui=1500Vdc; Uimp=8kV Ue: 300/600/800/1000 DC Ie: 8A...25A
PEDS150a-b16c-y Series	Similar to PEDS150a-b32c-y Series except rated: Ui=1500Vdc; Uimp=8kV Ue: 300/600/800/1000 DC Ie: 6A...16A

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Old Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 08-07-20 190350/2a
Correction to General Modification

www.jas-anz.org/register



14 February 2019

ProJoy Electric Co., Ltd.
XinTang Industrial Zone,
North-city Street, PingJiang District,
Suzhou 215000
P.R. China

C/- ICAL & TRADING CO

Dear Sir

Certificate of Conformity – SAA-190350-EA
PV Switch-disconnector
Model No.: PEDS150a-b32c-y Series

We are pleased to advise that your application for certification of the above electrical product has been successful.

Please ensure that you keep the enclosed Certificate in a safe place as it is your product approval record.

The certified product must now be marked with the Regulatory Compliance Mark (RCM) and may also be marked with the SAA Number SAA-190350-EA. The RCM must be used in accordance with the conditions set out in the relevant parts of AS/NZS 4417.

Please note that if the electrical product is modified in any way or your company details change you are required to notify this office of the details of the modification. You can either download the required form from our web page or contact our office.

As part of our operational guidelines we are required to check that a certified product remains compliant during the term of the Certificate. At some stage during this term we may request a sample for evaluation.

If you need any further information or need to discuss this letter please don't hesitate to contact our office.

Yours sincerely

A handwritten signature in black ink, appearing to be 'JH'.

For and on behalf of
SAA Approvals Pty Ltd

ABN 91 125 451 327

P. +61 7 3393 9455

F. +61 7 3393 9499

E. info@saaapprovals.com.au

W. www.saaapprovals.com.au

PO Box 189, Cannon Hill QLD 4170
5/20 Rivergate Place, Murarrie QLD 4172



APPROVALS®

Certificate of Conformity

Addendum

Certificate No.: SAA-190350-EA

Date of Issue: 2 April 2020

Regulatory Definition: DC Isolator
Product Description: PV Switch-disconnector

General Modification:

Use of alternative construction, where 'y' in model number denotes different switching circuit and can also be '3', '6' or '8'.

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 02-04-20 190350/3



2 April 2020

ProJoy Electric Co., Ltd.
XinTang Industrial Zone,
North-city Street,
PingJiang District,
Suzhou 215000
P.R. China

C/- ICAL & TRADING CO

Dear Certificate Holder

**Modification to Certificate – SAA-190350-EA
PV Switch-disconnector
Model No.: PEDS150a-b32c-y Series**

We hereby advise that your application for modification to the above electrical product has been accepted.

The enclosed certificate should be stored with the original certificate as evidence of certification.

As a reminder please note that all products approved under this certificate must now be marked with the Regulatory Compliance Mark (RCM) and may also be marked with the SAA Number SAA-190350-EA. The RCM must be used in accordance with the conditions set out in the relevant parts of AS/NZS 4417.

If you need any further information or need to discuss this letter please don't hesitate to contact our office.

Yours sincerely

A handwritten signature in black ink that reads 'R.A. Hill'.

**For and on behalf of
SAA Approvals Pty Ltd**

ABN 91 125 451 327

P. +61 7 3393 9455

E. +61 7 3393 9499

E. info@saaapprovals.com.au

W. www.saaapprovals.com.au

PO Box 189, Cannon Hill QLD 4170
5/20 Rivergate Place, Murarie QLD 4172