


## VERIFICATION OF LVD COMPLIANCE

Applicant: ProJoy Electric Co., Ltd.  
Address of applicant: Room 3017, 3018, 30th Floor, Tiancheng Times Business Plaza,  
Xiangcheng District, Suzhou, China  
Manufacturer: ProJoy Electric Co., Ltd.  
Room 3017, 3018, 30th Floor, Tiancheng Times Business Plaza,  
Xiangcheng District, Suzhou, China  
Product Description: Firefighter Safety Switches  
Model No.: PEFS-EL16-2/4/4B/4S/4T/6/8; PEFS-EL25-2/4/4B/4S/4T/6/8;  
PEFS-EL32-2/4/4B/4S/4T/6/8; PEFS-EL40-2/4/4B/4S/4T/6/8  
PEFS-EL55-2/4/4B/4S/4T/6/8;  
PEFS-EL50H-2/4/6/8/10/4B/4T/4S/6T/9T  
PEFS-EL40H-2/4/6/8/10/4B/4T/4S/6T/9T  
Rating: DC voltage: 300~1500V, DC current: 9~55A, 1~5 strings;  
AC voltage: 100~270V, AC current: 30~300mA;  
Protection level: IP66  
Sufficient samples of the product have been tested and found to be in conformity with  
Test Standard: EN IEC 61058-1:2018  
As shown in the  
Test Report Number(s): TLJS20090726744  
Date of issue: September 11<sup>th</sup>, 2020  
Date of expiry: September 10<sup>th</sup>, 2025

### Conclusion

This Verification of LVD Compliance has been granted to the applicant based on the results of the TCF, performed by Global Testing Services Co., Ltd. on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/35/EU. The CE mark as shown below can be used, under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

Approved by: Hermann Weiher



For and on behalf of  
Global Testing Services Co., Ltd



Global Testing Services Co., Ltd  
E-mail: info@gts-lab.com <http://www.gts-lab.com>  
Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.