



Ref. Certif. No.

HU-002544

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

DC Miniature Circuit Breaker

Name and address of the applicant

ProJoy Electric Co., Ltd.
XinTang Industrial Zone, North-city Street,
PingJiang District, Suzhou 215000, P.R. China

Name and address of the manufacturer

ProJoy Electric Co., Ltd.
XinTang Industrial Zone, North-city Street,
PingJiang District, Suzhou 215000, P.R. China

Ratings and principal characteristics

Cat. A; Ue: DC 80V (1P), DC 160V (2P);
In= 10, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125A;
Ui= 500V; Icu= 10kA; Ics= 7,5kA;
Instantaneous tripping curve: Ii= 8In (for C-type),
Ii= 4In (for B-type)
(see Test item particulars and General product
information of Test Report for further details)

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

PEBS-L

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

1W181329

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.com



Date: 2019-04-02

Signature:

Gabor Kassai
Gabor Kassai