

Ref. Certif. No.

HU-002584

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used Model /

Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

DC Miniature Circuit Breaker

ProJoy Electric Co., Ltd. XinTang Industrial Zone, North-city Street, PingJiang District, Suzhou 215000, P.R. China

ProJoy Electric Co., Ltd. XinTang Industrial Zone, North-city Street, PingJiang District, Suzhou 215000, P.R. China

Cat. A; 1P/2P/3P/4P; Ue=250V/500V/750V/1000V DC (1/2/3/4P); In=10, 16, 20, 25, 32, 40, 50, 63A; Ui=1000V; Uimp=6,0kV; Icu=6,0kA; Ics=6,0kA; Instantaneous tripping curve: Ii=8In(for C-type), Ii=4In(for B-type) (see Test item particulars and General product information of Test Report for further details)


PROJOY

PEBS-H

IEC 60947-2:2016

1W181134

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., Division MEE H-1132 Budapest, Váci út 48/A-B www.tuv.com

Rheinland Inter

duct Certifica

3

Gabor Kassai

Signature: