

IEC**IECEE**

®

TM

Ref. Certif. No.

HU-003400

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	DC MCCB
Name and address of the applicant	ProJoy Electric Co., Ltd. XinTang Industrial Zone, North-city Street, PingJiang District, Suzhou, 215000 Jiangsu, P.R. China
Name and address of the manufacturer	ProJoy Electric Co., Ltd. XinTang Industrial Zone, North-city Street, PingJiang District, Suzhou, 215000 Jiangsu, P.R. China
Name and address of the factory	Jiangsu Projoy Electric Co., LTD NO.2266 Tai Yang Road, Xiangcheng District, Suzhou, Jiangsu, P.R. China
Ratings and principal characteristics	Cat. A; 2P Appearance; Reference temperature: +40 °C Ui=1000V; Uimp=8kV; thermal, electromagnetic release; Ue=DC 500V; In= 125, 140, 160, 180, 200, 225, 250A; Icu=20kA; Ics=10kA
Trademark (if any)	PROJOY
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	PEMC-250
Additional information (if necessary may also be reported on page 2)	Detailed information refer to test report CN21EEPN 001.
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	CN21EEPN 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2021-04-15

Signature: Wencai Zhang