

Verification No.: CLJS23030344669



VERIFICATION OF LVD COMPLIANCE

Applicant: Projoy Electric Co., Ltd.
Address of applicant: No. 2266, Taiyang Road, Xiangcheng District, Suzhou, China
Manufacturer: Projoy Electric Co., Ltd.
No. 2266, Taiyang Road, Xiangcheng District, Suzhou, China
Product Description: AC Switch-disconnector
Model No.: PEAS69N-abx-c-y, PEAS69-abx-c-y, PEAS50-ab-c
Rating: See the annex
Sufficient samples of the product have been tested and found to be in conformity with
Test Standard: EN IEC 60947-3:2021
As shown in the
Test Report Number(s): TLJS23030344669
Date of issue: March 10, 2023
Date of expiry: March 09, 2028

Conclusion

This Verification of LVD Compliance has been granted to the applicant based on the results of the TCF, performed by Global Testing Services Co., Ltd. on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/35/EU. The CE mark as shown below can be used, under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

Approved by: Hermann Weiher

For and on behalf of
Global Testing Services Co., Ltd



Global Testing Services Co., Ltd
E-mail: info@gts-lab.com <http://www.gts-lab.com>
Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.

Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.

VERIFICATION OF LVD COMPLIANCE

Annex

PEAS69N-abx-c-y

a=PM,DC,LK,EL;

b=16,20,25,32,40,63,80,100;

x=Blank,R;

c=3,4;

y=RY64,B64;

Ui=690V;Ue=240V,440V;Uimp=8kV;Load type=AC-21A/AC-22A/AC-23A

PEAS69-abx-c-y

a=PM,DC,LK,EL;

b=20,32,40,63,80;

x=Blank,R;

c=3,4;

y=RY48,RY64,B48,B64;

Ui=690V;Ue=240V,440V;Uimp=8kV;Load type=AC-23A/AC-3

PEAS50-ab-c


a=EL;

b=20,35,63;

c=1N,2N,3N;

Ui=500V;Ue=250V,440V;Uimp=4kV;Load type=AC-22A

Approved by: Hermann Weiher



For and on behalf of
Global Testing Services Co., Ltd



Global Testing Services Co., Ltd

E-mail: info@gts-lab.com <http://www.gts-lab.com>

Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.

Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.